



## MET Laboratories, Inc.

Baltimore, MD    Union City, CA    Santa Clara, CA  
410-354-3300    510-489-6300    408-748-3585

[www.metlabs.com](http://www.metlabs.com)

December 18, 2007

Stephen Illenberger  
Cheval Electronic Enclosure Co., LTD.  
145 Moo 17 Bangplee Industrial Estate  
Bangsaothong, Bangplee, Samutprakam 10540

Dear Mr. Illenberger,

Congratulations! It is our pleasure to inform Cheval Electronic Enclosure Co., LTD. that the 600x1000 mm 19" EIA Seismic Rack, as will be defined in the MET Laboratories' Test Report ESLU80561, has successfully completed and is compliant with the following tests, performed at MET Laboratories, Inc.:

***Telcordia Technologies' GR-63-CORE, Issue 3, March 2006:***

- **Section 4.4.2 - Framework and Anchor Criteria**
- **Section 4.4.1.2 – Physical Performance Criteria, Waveform Test – Zone 4 Profile**

***ANSI T1.336-2003 Engineering Requirements for a Universal Telecom Framework***

***ANSI T1.329-2002 Network Equipment Earthquake Resistance***

Please contact me with any questions or comments.

Sincerely,

Rajnesh Nand  
Project Engineer, Environmental Simulation Laboratory  
[rmand@metlabs.com](mailto:rmand@metlabs.com)